

烟气排放连续监测小时平均值日报表

排放源名称：鄂尔多斯市西北能源化工有限责任公司 1#炉

排放源编号：abcd-1234

监测日期：2019年04月29日

时间	颗粒物			SO2			NOx			标态流量 m3/h	氧量 %	烟温 ℃	含湿量 %	负荷 %	备注
	mg/m3	折算 mg/m3	kg/h	mg/m3	折算 mg/m3	kg/h	mg/m3	折算 mg/m3	kg/h						
00~01	14.45	14.45	0	0.4	0.4	0	0	0	0	0	21.29	22.54	2.75	/	
01~02	15.14	15.14	0	0.44	0.44	0	0	0	0	0	21.27	22.1	2.76	/	
02~03	15.35	15.35	0	0.41	0.41	0	0	0	0	0	21.24	21.65	2.72	/	
03~04	14.88	14.88	0	0.4	0.4	0	0	0	0	0	21.24	21.24	2.73	/	
04~05	16.01	16.01	0	0.42	0.42	0	0	0	0	0	21.23	20.86	2.74	/	
05~06	18.71	18.71	0	0.41	0.41	0	0	0	0	0	21.23	20.51	2.7	/	
06~07	15.92	15.92	0	0.43	0.43	0	0	0	0	0	21.24	20.22	2.7	/	
07~08	15.54	15.54	0	0.42	0.42	0	0	0	0	0	21.27	20.32	2.71	/	
08~09	15.62	15.62	0.08	0.42	0.42	0	0	0	0	4,859.66	21.28	21.12	2.67	/	
09~10	17.44	17.44	0	0.43	0.43	0	0	0	0	0	21.29	21.85	2.67	/	
10~11	17.22	17.22	0	0.41	0.41	0	0	0	0	0	21.3	22.37	2.64	/	
11~12	15.1	15.1	0	0.43	0.43	0	0	0	0	0	21.32	23.08	2.58	/	
12~13	12.78	12.78	0	0.41	0.41	0	0	0	0	0	21.31	23.85	2.55	/	
13~14	12.48	12.48	0	0.45	0.45	0	0	0	0	0	21.3	24.59	2.56	/	
14~15	14.25	14.25	0	0.46	0.46	0	0	0	0	0	21.29	25.35	2.51	/	
15~16	12.53	12.53	0	0.48	0.48	0	0	0	0	0	21.28	25.58	2.53	/	
16~17	12.64	12.64	0	0.48	0.48	0	0	0	0	0	21.28	25.54	2.54	/	
17~18	11.94	11.94	0	0.5	0.5	0	0	0	0	0	21.31	25.22	2.53	/	
18~19	11.96	11.96	0	0.54	0.54	0	0	0	0	0	21.34	24.28	2.51	/	
19~20	11.31	11.31	0	0.49	0.49	0	0	0	0	0	21.38	23.18	2.49	/	
20~21	11.11	11.11	0	0.52	0.52	0	0	0	0	0	21.42	22.36	2.48	/	
21~22	11.07	11.07	0	0.47	0.47	0	0	0	0	0	21.47	21.51	2.51	/	
22~23	10.99	10.99	0	0.46	0.46	0	0	0	0	0	21.49	20.5	2.53	/	
23~24	10.87	10.87	0	0.45	0.45	0	0	0	0	0	21.49	19.42	2.5	/	
平均值	13.97	13.97	0	0.45	0.45	0	0	0	0	202.49	21.32	22.47	2.61	/	
最大值	18.71	18.71	0.08	0.54	0.54	0	0	0	0	4,859.66	21.49	25.58	2.76	/	
最小值	10.87	10.87	0	0.4	0.4	0	0	0	0	0	21.23	19.42	2.48	/	
样本数	24	24	24	24	24	24	24	24	24	24	24	24	24	/	
日排放总量	--		0	--		0	--		0	0.49	--	--	--	--	

烟气日排放总量单位：×10000 m3/d

上报单位： 负责人： 报告人： 报告日期： 年 月 日