

烟气排放连续监测小时平均值日报表

排放源名称：鄂尔多斯市西北能源化工有限责任公司 1#炉

排放源编号：abcd-1234

监测日期：2019年05月02日

时间	颗粒物			SO2			NOx			标态流量 m3/h	氧量 %	烟温 ℃	含湿量 %	负荷 %	备注
	mg/m3	折算 mg/m3	kg/h	mg/m3	折算 mg/m3	kg/h	mg/m3	折算 mg/m3	kg/h						
00~01	9.33	9.33	0	0.56	0.56	0	0	0	0	0	21.42	21.23	2.16	/	
01~02	9.03	9.03	0	0.56	0.56	0	0	0	0	0	21.41	21.12	2.15	/	
02~03	9.2	9.2	0	0.56	0.56	0	0	0	0	0	21.41	20.62	2.15	/	Md
03~04	9.36	9.36	0	0.56	0.56	0	0	0	0	0	21.4	20.11	2.14	/	
04~05	9.35	9.35	0	0.61	0.61	0	0	0	0	0	21.41	19.1	2.17	/	
05~06	9.18	9.18	0	0.5	0.5	0	0	0	0	0	21.41	18.46	2.16	/	
06~07	9.4	9.4	0	0.59	0.59	0	0	0	0	0	21.44	17.8	2.18	/	
07~08	203.7	203.7	0	0.52	0.52	0	0	0	0	0	21.48	18.2	2.19	/	
08~09	136	136	0	0.54	0.54	0	0	0	0	0	21.5	19.52	2.18	/	
09~10	138.7	138.7	0.02	0.53	0.53	0	0	0	0	130.87	21.51	20.92	2.2	/	
10~11	56.88	56.88	0.52	0.54	0.54	0	0	0	0	9,147.33	21.51	21.82	2.2	/	
11~12	114.2	114.2	2.48	0.54	0.54	0.01	0	0	0	21,753.32	21.48	21.89	2.16	/	
12~13	6.18	6.18	0.07	0.51	0.51	0.01	0	0	0	10,611.92	21.45	22.46	2.15	/	
13~14	85.61	85.61	0.45	0.51	0.51	0	0	0	0	5,309.68	21.42	23.17	2.12	/	Md
14~15	165	165	0	0.51	0.51	0	0	0	0	7.45	21.38	23.88	2.08	/	
15~16	143.5	143.5	0	0.53	0.53	0	0	0	0	0	21.33	24.33	2.1	/	
16~17	131.2	131.2	0	0.54	0.54	0	0	0	0	0	21.3	24.81	2.1	/	
17~18	186.5	186.5	0	0.58	0.58	0	0	0	0	0	21.29	24.67	2.08	/	
18~19	189.1	189.1	0	0.5	0.5	0	0	0	0	0	21.28	24.49	2.08	/	
19~20	191	191	0	0.52	0.52	0	0	0	0	0	21.29	24.06	2.09	/	
20~21	193	193	0	0.54	0.54	0	0	0	0	0	21.33	24.06	2.08	/	
21~22	192.7	192.7	0	0.53	0.53	0	0	0	0	7.44	21.36	24.12	2.06	/	
22~23	191.9	191.9	0	0.52	0.52	0	0	0	0	0	21.38	24.55	2.07	/	
23~24	191.6	191.6	0	0.59	0.59	0	0	0	0	14.88	21.39	23.96	2.07	/	
平均值	107.6	107.6	0.15	0.54	0.54	0	0	0	0	1,957.62	21.4	22.06	2.13	/	
最大值	203.7	203.7	2.48	0.61	0.61	0.01	0	0	0	21,753.32	21.51	24.81	2.2	/	
最小值	6.18	6.18	0	0.5	0.5	0	0	0	0	0	21.28	17.8	2.06	/	
样本数	24	24	24	24	24	24	24	24	24	24	24	24	24	/	
日排放总量	—		0	—		0	—		0	4.7	—	—	—	—	

烟气日排放总量单位：×10000 m3/d

上报单位： 负责人： 报告人： 报告日期： 年 月 日