

烟气排放连续监测小时平均值日报表

排放源名称：鄂尔多斯市西北能源化工有限责任公司 1#炉

排放源编号：abcd-1234

监测日期：2019年05月03日

时间	颗粒物			SO2			NOx			标态流量 m3/h	氧量 %	烟温 ℃	含湿量 %	负荷 %	备注
	mg/m3	折算 mg/m3	kg/h	mg/m3	折算 mg/m3	kg/h	mg/m3	折算 mg/m3	kg/h						
00~01	192.5	192.5	0	0.52	0.52	0	0	0	0	0	21.38	23.84	2.09	/	
01~02	192.5	192.5	0	0.55	0.55	0	0	0	0	0	21.38	24.11	2.11	/	
02~03	193.1	193.1	0	0.56	0.56	0	0	0	0	0	21.38	23.42	2.04	/	
03~04	193.8	193.8	0	0.61	0.61	0	0	0	0	0	21.38	23.11	2.07	/	
04~05	195.6	195.6	0	0.6	0.6	0	0	0	0	0	21.38	22.57	2.07	/	
05~06	195.8	195.8	0.97	0.53	0.53	0	0	0	0	4,966.95	21.39	22.18	2.05	/	
06~07	188.7	188.7	0	0.58	0.58	0	0	0	0	0	21.42	21.94	2.07	/	
07~08	171.9	171.9	0	0.61	0.61	0	0	0	0	0	21.43	22.14	2.09	/	
08~09	190.1	190.1	0	0.62	0.62	0	0	0	0	0	21.44	22.93	2.07	/	
09~10	174	174	0	0.58	0.58	0	0	0	0	0	21.45	23.87	2.11	/	
10~11	174.3	174.3	0	0.56	0.56	0	0	0	0	0	21.45	24.74	2.13	/	
11~12	337.6	337.6	0.06	0.55	0.55	0	0	0	0	181.17	21.42	25.41	2.11	/	Md
12~13	501	501	0.18	0.54	0.54	0	0	0	0	362.35	21.4	26.08	2.09	/	
13~14	423.8	423.8	0.31	0.52	0.52	0	0	0	0	734.02	21.37	26.48	2.08	/	
14~15	236.7	236.7	0	0.54	0.54	0	0	0	0	14.47	21.33	27.27	2.02	/	
15~16	374.2	374.2	0.06	0.52	0.52	0	0	0	0	169.02	21.3	27.67	2.04	/	
16~17	339.5	339.5	0.03	0.47	0.47	0	0	0	0	100.91	21.27	27.36	2.05	/	
17~18	255.8	255.8	0	0.58	0.58	0	0	0	0	0	21.26	27.49	2.03	/	
18~19	221.5	221.5	0	0.59	0.59	0	0	0	0	0	21.25	27.47	2.06	/	
19~20	497.3	497.3	0	0.56	0.56	0	0	0	0	0	21.27	27.39	2.06	/	
20~21	500.8	500.8	0	0.53	0.53	0	0	0	0	0	21.3	26.87	2.03	/	
21~22	500.8	500.8	2.45	0.48	0.48	0	0	0	0	4,886.54	21.32	26.57	2.05	/	
22~23	500.8	500.8	0	0.53	0.53	0	0	0	0	0	21.33	26.62	2.07	/	
23~24	500.8	500.8	0	0.63	0.63	0	0	0	0	0	21.33	26.19	2.04	/	
平均值	302.2	302.2	0.17	0.56	0.56	0	0	0	0	475.64	21.36	25.16	2.07	/	
最大值	501	501	2.45	0.63	0.63	0	0	0	0	4,966.95	21.45	27.67	2.13	/	
最小值	171.9	171.9	0	0.47	0.47	0	0	0	0	0	21.25	21.94	2.02	/	
样本数	24	24	24	24	24	24	24	24	24	24	24	24	24	/	
日排放总量	—		0	—		0	—		0	1.14	—	—	—	—	

烟气日排放总量单位：×10000 m3/d

上报单位： 负责人： 报告人： 报告日期： 年 月 日