

烟气排放连续监测小时平均值日报表

排放源名称：鄂尔多斯市西北能源化工有限责任公司 1#炉

排放源编号：abcd-1234

监测日期：2019年05月05日

时间	颗粒物			SO2			NOx			标态流量 m3/h	氧量 %	烟温 ℃	含湿量 %	负荷 %	备注
	mg/m3	折算 mg/m3	kg/h	mg/m3	折算 mg/m3	kg/h	mg/m3	折算 mg/m3	kg/h						
00~01	103.5	103.5	0	0.49	0.49	0	0	0	0	0	21.65	24.76	1.92	/	
01~02	103.6	103.6	0	0.49	0.49	0	0	0	0	0	21.69	23.79	1.94	/	
02~03	102.9	102.9	0	0.46	0.46	0	0	0	0	0	21.71	22.53	1.93	/	
03~04	103.2	103.2	0	0.53	0.53	0	0	0	0	0	21.72	21.03	1.96	/	
04~05	103.6	103.6	0	0.57	0.57	0	0	0	0	0	21.75	19.5	1.96	/	
05~06	103.4	103.4	0.53	0.58	0.58	0	0.01	0.01	0	5,086.65	21.78	18.1	1.94	/	
06~07	103.1	103.1	0	0.63	0.63	0	0	0	0	0	21.8	17.11	1.96	/	
07~08	78.42	78.42	0	0.58	0.58	0	0	0	0	0	21.84	16.94	1.97	/	
08~09	40.92	40.92	0	0.49	0.49	0	0	0	0	0	21.87	17.34	1.94	/	
09~10	39.97	39.97	0	0.54	0.54	0	0	0	0	0	21.87	17.85	1.97	/	
10~11	42.04	42.04	0	0.52	0.52	0	0	0	0	0	21.87	18.37	1.95	/	
11~12	46.12	46.12	0	0.56	0.56	0	0	0	0	0	21.85	19.47	1.91	/	
12~13	49.9	49.9	0	0.59	0.59	0	0	0	0	0	21.82	20.4	1.92	/	
13~14	49.94	49.94	0	0.56	0.56	0	0	0	0	0	21.79	21.37	1.89	/	
14~15	51.64	51.64	0	0.65	0.65	0	0	0	0	0	21.77	22.51	1.84	/	
15~16	51.22	51.22	0	0.63	0.63	0	0	0	0	0	21.74	23.14	1.85	/	
16~17	48.89	48.89	0	0.57	0.57	0	0	0	0	0	21.71	23.74	1.87	/	
17~18	45.02	45.02	0	0.6	0.6	0	0	0	0	0	21.71	23.75	1.85	/	
18~19	43.58	43.58	0	0.59	0.59	0	0	0	0	0	21.71	23.42	1.86	/	
19~20	43.6	43.6	0	0.67	0.67	0	0	0	0	0	21.73	22.7	1.88	/	
20~21	38.37	38.37	0	0.62	0.62	0	0	0	0	0	21.79	21.54	1.84	/	
21~22	36.95	36.95	0.19	0.61	0.61	0	0	0	0	5,068.12	21.81	20.68	1.86	/	
22~23	46.94	46.94	0	0.6	0.6	0	0	0	0	0	21.83	20.03	1.86	/	
23~24	44.35	44.35	0	0.56	0.56	0	0	0	0	0	21.84	19.22	1.83	/	
平均值	63.38	63.38	0.03	0.57	0.57	0	0	0	0	423.12	21.78	20.8	1.9	/	
最大值	103.6	103.6	0.53	0.67	0.67	0	0.01	0.01	0	5,086.65	21.87	24.76	1.97	/	
最小值	36.95	36.95	0	0.46	0.46	0	0	0	0	0	21.65	16.94	1.83	/	
样本数	24	24	24	24	24	24	24	24	24	24	24	24	24	/	
日排放总量	—		0	—		0	—		0	1.02	—	—	—	—	

烟气日排放总量单位：×10000 m3/d

上报单位： 负责人： 报告人： 报告日期： 年 月 日