

烟气排放连续监测小时平均值日报表

排放源名称：鄂尔多斯市西北能源化工有限责任公司 1#炉

排放源编号：abcd-1234

监测日期：2019年05月06日

时间	颗粒物			SO2			NOx			标态流量 m3/h	氧量 %	烟温 ℃	含湿量 %	负荷 %	备注
	mg/m3	折算 mg/m3	kg/h	mg/m3	折算 mg/m3	kg/h	mg/m3	折算 mg/m3	kg/h						
00~01	3.64	3.64	0	0.61	0.61	0	0	0	0	0	21.85	18.44	1.84	/	
01~02	3.68	3.68	0	0.66	0.66	0	0	0	0	0	21.84	17.89	1.82	/	
02~03	3.55	3.55	0	0.6	0.6	0	0	0	0	0	21.84	17.41	1.81	/	
03~04	3.66	3.66	0	0.67	0.67	0	0	0	0	0	21.84	16.67	1.82	/	
04~05	3.72	3.72	0	0.6	0.6	0	0	0	0	0	21.84	15.96	1.83	/	
05~06	3.67	3.67	0	0.6	0.6	0	0	0	0	0	21.86	15.11	1.81	/	
06~07	15.23	15.23	0	0.63	0.63	0	0	0	0	0	21.86	14.43	1.82	/	
07~08	57.86	57.86	0	0.74	0.74	0	0	0	0	0	21.86	15.06	1.82	/	
08~09	114.6	114.6	0	0.68	0.68	0	0	0	0	0	21.86	16.29	1.8	/	
09~10	256.2	256.2	0	0.64	0.64	0	0	0	0	0	21.85	17.62	1.81	/	
10~11	184.2	184.2	0	0.74	0.74	0	0	0	0	0	21.82	19.08	1.81	/	
11~12	55.34	55.34	0	0.67	0.67	0	0	0	0	30.07	21.8	20.34	1.79	/	
12~13	57.4	57.4	0	0.65	0.65	0	0	0	0	14.56	21.75	21.3	1.79	/	
13~14	55.91	55.91	0.28	0.73	0.73	0	0	0	0	5,083.27	21.7	22.13	1.78	/	
14~15	53.13	53.13	0	0.71	0.71	0	0	0	0	0	21.66	23.02	1.76	/	
15~16	6.96	6.96	0	0.77	0.77	0	0	0	0	0	21.62	23.88	1.77	/	
16~17	9.82	9.82	0	0.73	0.73	0	0	0	0	0	21.59	24.31	1.77	/	
17~18	13.73	13.73	0	0.7	0.7	0	0	0	0	0	21.57	24.36	1.75	/	
18~19	11.64	11.64	0	0.54	0.54	0	0	0	0	0	21.57	24.2	1.74	/	Md
19~20	9.55	9.55	0	0.38	0.38	0	0	0	0	0	21.57	24.03	1.74	/	
20~21	7.33	7.33	0	0.38	0.38	0	0	0	0	0	21.58	23.12	1.73	/	
21~22	7.19	7.19	0	0.37	0.37	0	0	0	0	0	21.59	22.53	1.74	/	
22~23	4.96	4.96	0	0.38	0.38	0	0	0	0	0	21.6	21.78	1.74	/	
23~24	4.09	4.09	0	0.38	0.38	0	0	0	0	0	21.6	20.94	1.71	/	
平均值	39.46	39.46	0.01	0.61	0.61	0	0	0	0	213.66	21.73	20	1.78	/	
最大值	256.2	256.2	0.28	0.77	0.77	0	0	0	0	5,083.27	21.86	24.36	1.84	/	
最小值	3.55	3.55	0	0.37	0.37	0	0	0	0	0	21.57	14.43	1.71	/	
样本数	24	24	24	24	24	24	24	24	24	24	24	24	24	/	
日排放总量	--		0	--		0	--		0	0.51	--	--	--	--	

烟气日排放总量单位：×10000 m3/d

上报单位： 负责人： 报告人： 报告日期： 年 月 日